

ATTACHMENT C

Additional Licensing Condition

Case No. 9600

In the Matter of the Application of Baltimore Gas and Electric Company (BGE) for a Certificate of Public Convenience and Necessity for the Key Crossing Reliability Initiative Transmission Line Project

Commission approval of a Certificate of Public Convenience and Necessity for the Key Crossing Reliability Initiative Transmission Line Project does not imply that a prudence or cost recovery determination was made regarding any future liability that may arise related to BGE's planned decommissioning of the existing submarine Harbor Crossing cable pipes as detailed in its Application and supporting materials.

Prior to commencing the decommissioning of the existing submarine Harbor Crossing cable pipes, BGE shall provide to PPRP and Staff a detailed decommissioning plan for review and comment. The plan shall include information on the potential for removal of the cable pipes in the future should other existing infrastructure in the Patapsco River bed located in proximity to the cable pipes need to be removed or replaced. The plan shall describe the procedures that BGE will incorporate to minimize the risk of failure of the cable pipes under future conditions and any impacts that could result therefrom. The plan shall discuss the feasibility of continuing cathodic protection and whether such continued protection of decommissioned pipes can be considered reasonable and prudent. The plan shall also provide for future reporting by BGE should BGE become aware of any new technology or method for testing the integrity of buried pipes, or should BGE come aware that the condition of the cable pipes has deteriorated to the point of

likely failure. In the event any party is unsatisfied with the proposed decommissioning plan as set forth by BGE, the party may seek revisions to the plan and a determination from the Commission as to a final decommissioning plan. In the event of a future failure of the cable pipes, if a liability is imposed on BGE as a result of its decision to abandon the cable pipes under the Patapsco River bed and BGE seeks to recover associated costs in customer rates, BGE shall seek a prudence and cost recovery determination from the appropriate state or federal agency and notify PPRP, Staff, and OPC of such filing when made.